



City of Bristol
BRISTOL, CONNECTICUT 06010

Invitation to Bid 2011-091
Playground Improvements at Stafford Elementary School
Addendum 02
May 5, 2011

Please note the following changes:

Erroneous reference to "poured in place concrete surface" on Page 1 of the original specification is replaced with "rubber safety surfacing".

The Contractor shall construct a berm one foot (1') in height at the end of the location for the installed ramp, to accommodate a 1-to-20 grade for said ramp.

Additionally, the Contractor shall construct a bituminous walkway at the edge of the installed ramp, with walkway consisting of 3" Class 2 bituminous on 6" processed gravel base. Walkway shall be 5' in width and shall extend from the ramp to the existing sidewalk (20 feet in overall length).

The Contractor shall grade areas adjacent to walkway into remaining naturalized area, and reseed graded area.

Chain link fencing on the site may be removed for the purpose of performing work as required in this scope. The Contractor is required to return to its original condition any fencing removed as part of this contract.

The Contractor is required to remove the existing sand box as part of the area preparation.

Any ruts caused by the use of construction vehicles on the school lawn shall be repaired by the contractor at its sole expense.

The Contractor is permitted to perform work during normal working hours in the following time frames: 6:30am to 8:30am, 9:00am to 11:30am, 12:45 to 2:45pm, and 3:45pm to 6:00pm. Vehicle traffic outside of these windows is restricted to accommodate vehicles related to pickup and drop-off of students.

All other terms and conditions remain unchanged.

Roger D. Rousseau
Purchasing Agent
Tel (860) 584-6195
Fax (860) 584-6171

