



City of Bristol
BRISTOL, CONNECTICUT 06010

**Invitation to Bid 2C11-049
Improvements to Broad Street Pumping Station
SCADA and Control Upgrades
Addendum 01
December 6, 2010**

Please note the following changes:

The bid due date is changed from Thursday December 9, 2010 at 3:00pm to Tuesday December 14, 2010 at 11:00am; please note that both the date and the time have been changed.

Section 01012-3

Change "the Contractor shall furnish and install an Ethernet [HUB] ROUTER and connect the new PLC to the City's existing cable modem located in the Generator Building."

Section 13311-9 subsection 2.04B

In place of "16-point discrete input Module (120/230 Vac Isolated Input Module)", insert "16 DI Fast 24V IEC 61131-2 Type II".

All other terms and conditions remain unchanged.

A handwritten signature in black ink, appearing to read "Roger D. Rousseau".

Roger D. Rousseau

Purchasing Agent

Tel (860) 584-6195

Fax (860) 584-6171

RETURN THIS FORM IMMEDIATELY!

City of Bristol, Connecticut
Acknowledgment: Receipt of Bid Documents

Bid Number: **2C11-049**

Title: **Improvements to Broad Street Pumping Station
SCADA and Control Upgrades
Addendum 01**

Please take a moment to acknowledge receipt of the attached bid documents. Your compliance with this request will help us to maintain proper follow-up procedures while ensuring that all recipients have the opportunity to submit proposals.

Date Addendum 01 was issued December 6, 2010

Date Addendum 01 was received ____/____/____

Do you plan to submit a bid? Yes____ No____

Print or type the following information:

Company name: _____

Address: _____

City or Town: _____

Phone: _____

Fax: _____

Email: _____

Received by: _____

**Note: Faxed acknowledgments are requested!
FAX (860)584-6171
A cover sheet is NOT necessary.
IMPORTANT: DO NOT FAX PROPOSALS.
PROPOSALS MUST BE SUBMITTED IN SEALED PACKAGES**